

AIR CONDITIONING UNIT SCHEDULE						
UNIT	DESCRIPTION	COOLING CAPACITY BTU/HR	UNIT DESIGNATION	ELECTRICAL		
				PHASE	VOLT	HERTZ
ACU 1	1.5 HP WALL MOUNTED SPLIT TYPE (INVERTER)	16,000.00	MANAGER'S OFFICE	1	230	60
ACU 2	2 HP WALL MOUNTED SPLIT TYPE (INVERTER)	20,000.00	BACK OFFICE	1	230	60
ACU 3	1.5 HP WINDOW TYPE (INVERTER)	12,000.00	PANTRY	1	230	60
ACU 4	3 TR FLOOR MOUNTED SPLIT TYPE (INVERTER)	36,000.00	CUSTOMER'S LOUNGE	1	230	60
ACU 5	3 TR FLOOR MOUNTED SPLIT TYPE (INVERTER)	36,000.00	CUSTOMER'S LOUNGE	1	230	60
ACU 6	3 TR FLOOR MOUNTED SPLIT TYPE (INVERTER)	36,000.00	CUSTOMER'S LOUNGE	1	230	60

VENTILATING UNIT SCHEDULE								
UNIT	DESCRIPTION	CAPACITY CMH	CONSUMPTION W	DUCT SIZE MM	UNIT DESIGNATION	ELECTRICAL		
						PHASE	VOLT	HERTZ
EXH1	CEILING MOUNTED EXHAUST TYPE	80	11	100	FEMALE TOILET	1	230	60
EXH2	CEILING MOUNTED EXHAUST TYPE	80	11	100	MALE TOILET	1	230	60
EXH3	CEILING MOUNTED EXHAUST TYPE	80	11	100	MALE TOILET	1	230	60
EXH4	CEILING MOUNTED EXHAUST TYPE	80	11	100	FEMALE TOILET	1	230	60

1 AIR CONDITIONING AND VENTILATING LAYOUT
M1 | M1 NOT TO SCALE

SATISFACTORY TO:


KENNETH LEMUEL G. REMENTILLA
DA FOR BUSINESS GROUP

PROJECT TITLE: **PROPOSED ONE-STOP SHOP AT BLDG. 332**

LOCATION: BURGOS STREET CBD AREA, SBFZ

SHEET NO. **M1**

20 OF 23



DRAFT/CADD: JAT
DESIGNED: JAT

CHECKED BY: **EDISON D. ICO**
DIV CHIEF III, PDD

REVIEWED BY: **GARY P. FERNANDEZ**
MANAGER, ENG'G DEPT

RECOMMENDED: **MARCO A. ESTABILLO**
DA FOR PWT&G

APPROVED: **ATTY. WILMA T. EISMA**
CHAIRMAN AND ADMINISTRATOR

